



City of New London

Department of Finance-Purchasing Agent
13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

Invitation for Bids

ADDENDUM

Bid No.: 2016-10

Addendum No.: 1

Date Issued: March 30, 2016

Pequot Avenue Storm Drainage – Design Services

Opening Date and Time: April 7, 2016 at 2:00 P.M.

Bidders Notes: This addendum is issued to provide all bidders with answers to submitted questions:

Question: Raising the elevation of Pequot Avenue could have significant impacts on adjacent properties. What limits of reconstruction does the City anticipate and to what elevation?

- 1) Yes, raising the elevation of the gutter line profile of Pequot Avenue could have significant impacts on the surrounding areas. It is our request that minor elevation changes to the Pequot Avenue profile be proposed to provide adequate gutter drainage that does not impact surrounding properties.

Question: What level of effort does the City expect the Consultant to perform to address localized flooding upstream of the Park (survey, hydrology, hydraulics, etc...)?

- 2) To perform a hydrologic study of the entire watershed that feeds into the proposed pipe, the City expects the Consultant to study a large area upstream of the Park, including the existing storm pipe network in the watershed.

All other terms and conditions remain the same.

This Addendum cover page must be signed and returned with your bid.

Authorized Signature of Bidder

Company Name

Return Bid To:

Alicia Smith, Purchasing Agent
City of New London
13 Masonic Street
New London, CT 06320

Bids cannot be accepted after the Bid Opening Date and Time indicated above.